

Plumbing and Drainage Regulation 2019, part 4.

#### **Approval**

- 1. The PABS 1500 ("the system") described in the Specifications and Drawings in the attached Schedule, manufactured and supplied by Taylex Pty Ltd (ABN 43 646 051 989) ("the manufacturer"), has been assessed in accordance with:
  - (a) section 19 of the Plumbing and Drainage Regulation 2019
  - (b) the Queensland Plumbing and Wastewater Code published on 26 June 2025.
- 2. A Treatment Plant Approval (TPA) is granted for an **Advanced secondary quality** wastewater treatment system subject to compliance by the manufacturer with the requirements of the *Plumbing* and *Drainage Act 2018* and the conditions of approval detailed below.
- 3. This approval, the conditions of approval, and the Schedule comprise the entire TPA document.
- 4. Any modification by the manufacturer/supplier to the design, drawings or specifications scheduled to this approval must be approved by the Chief Executive.

#### **Conditions of approval**

- 5. The manufacture, installation, operation, service, and maintenance of the system must conform with the conditions of this TPA.
- 6. The system, when tested against AS 1546.3:2017 and assessed by a certification accreditation body, was found to comply with the **Advanced secondary quality**, 1500 L/day level. The system must continue to meet the following effluent criteria:

Table 2.1 (Abrev) AS1546.3:2017 Advanced secondary effluent compliance criteria for an STS

Parameter	Advanced secondary effluent			
	90% of Samples	Maximum		
BOD⁵	≤ 10 mg/L	20 mg/L		
TSS	≤ 10 mg/L	20 mg/L		
E. coli*	≤ 10 cfu/100 mL	30 cfu/100 mL		
FACÞ	Minimum 0.5 mg/L <sup>†</sup>	N/A		
Turbidity §	N/A	10 NTU		

<sup>\*</sup> Where disinfection is required



<sup>▶</sup> Where chlorine disinfection is required

<sup>†</sup> Minimum level, not 90% of samples

<sup>§</sup> Where UV light is used for disinfection



#### Plumbing and Drainage Regulation 2019, part 4.

- 7. Each system installed must be serviced in accordance with the Certificate of Conformance, certificate number 7297-3039-01 issued by Global Certification Pty Ltd on 22 May 2025, and details supplied in the owner's operation and maintenance manual.
- 8. Each system must be supplied with
  - a. a copy of this TPA document
  - b. details of the system
  - c. instructions for authorised persons for its installation
  - d. a copy of the owner's manual to be given to the owner at the time of installation
  - e. detailed instructions for authorised service personnel for its operation and maintenance.
- 9. At each anniversary of the TPA issue date, the manufacturer/supplier must submit to the Chief Executive, a list of all systems installed in Queensland during the previous 12 months. Where the Chief Executive is notified of any system failures, the Chief Executive may randomly select several installed systems for audit. The Chief Executive will notify the supplier's nominated NATA accredited laboratory which systems are to be audited for BOD<sup>5</sup> and TSS. The sampling and testing of the selected systems are to be done at the supplier's expense. The following results must be reported to the Chief Executive:
  - a. Address of premises
  - b. Date inspected and sampled
  - c. Sample identification number
  - d. BOD<sup>5</sup> for influent and effluent
  - e. TSS for influent and effluent.
- 10. The Chief Executive may, by written notice, cancel this TPA if the manufacturer/supplier fails:
  - a. to comply with one or more of the conditions of approval, or
  - b. within 30 days, to remedy a breach for which a written notice been given by the Chief Executive.
- 11. This approval may only be assigned with the prior written consent of the Chief Executive.
- 12. This approval expires on **14 October 2030** unless cancelled earlier in accordance with paragraph 10 above.

Steve Storer



Level 15, 53 Albert Street Brisbane GPO Box 2457, Brisbane Qld 4001 **Website** www.hpw.qld.gov.au

ABN 61 331 950 314

#### A/Director

Strategic Policy Plumbing, Drainage and Special Projects Date approved: 14 October 2025





Plumbing and Drainage Regulation 2019, part 4.

#### **SCHEDULE**

**PABS 1500** 

Attachment 1 - Global Certification Certificate 7297-3039-01

Attachment 2 - PABS 1500 - Owner's manual

Attachment 3 – PABS 1500 – Schematic diagrams





Plumbing and Drainage Regulation 2019, part 4.

Attachment 1 - Global Certification Certificate 7297-3039-01



#### **Taylex Australia Pty Ltd**

56 Prairie Road, Ormeau, QLD 4208, Australia

## **Product Testing**

AS 1546.3:2017

Advanced Secondary 1500 L/day or 10EP Level with Nitrogen reduction of 11% and Phosphorus reduction of 17.83%

Model	Disinfection	Average Results over the Test Period	Servicing Frequency	Discharge	Manufactured and assembled
Taylex Concrete ABS 1500 and Taylex Poly ABS 1500	Yes	TSS 7.6mg/l BOD5 1.5mg/l E coli 1.4 CFU/100ml Nitrogen 62.66mg/l Phosphorus 10.19mg/l	3 Monthly Service 3.2 yearly sedimentation pump out or as required	Pumped via disinfection/pump chamber with chlorine dispenser	56 Prairie Road, Ormeau, QLD 4208, Australia

The system took 4 weeks to meet the advanced secondary standard.

Note: The Ecoli result was compliant for the entire period from installation.

The vertical axis tanks are certified to AS/NZS 1546.1:2008 for both the Poly and Concrete systems

This Certificate of Conformance to the Product Certificate Scheme for "Domestic Wastewater Treatment Units and Rainwater Tanks" remains the property of Global Certification Pty. Ltd. and is granted subject to the terms and conditions of the Contract Application, in respect of the Product certified on this page and the attached schedule to the Certification of Conformance, bearing the same number as this certificate.

Evan Miller - General Manager Global Certification Pty Ltd

CERTIFICATION DATE: DATE OF ISSUE: 19 August 2020 22 May 2025

DATE OF ISSUE: EXPIRY DATE: 22 May 2025 19 August 2030

CERTIFICATE #: 7297-3039-01

JAS-ANZ



Global Certification Pty Ltd
1C, 60 Enterprise Place, Tingalpa, QLD 4173, Australia
1300 495 855 | www.globalcertification.com.au

Global Certification Pty Ltd is accredited by The Joint Accreditation System of Australia and New Zealand (www.ias-anz.ore/register) - accreditation number: 2448041040





Plumbing and Drainage Regulation 2019, part 4.


Attachment 2 – PABS 1500 – Owner's manual







## **TREATMENT PLANT APPROVAL 17/2025** *Plumbing and Drainage Regulation 2019*, part 4.





Plumbing and Drainage Regulation 2019, part 4.



## **Contents**

Trust Taylex	4
What is a Wastewater Treatment System	6
How does my Taylex System work?	8
What Keeps my System Healthy?	12
What Upsets the Balance in my System?	13
Suitable Products	14
Products to Avoid	17
Servicing your Taylex System	18
Operating Instructions - ABS Eco Controller	19
Optional Back to Base Alarm Modem	21
Alarm Codes (Trouble Shooting)	22
Resetting your Tayley System Troubleshooting and Warranty	25





Plumbing and Drainage Regulation 2019, part 4.

## **Trust Taylex**

Taylex is a proud, family-owned Australian leader in wastewater, rainwater, and stormwater management. Since 1969, we've turned water challenges into smart, sustainable solutions with a trusted, end-to-end approach. Backed by over 55 years of expertise and a nationwide network of skilled technicians, our locally designed and manufactured systems are built tough, run smoothly, and stand the test of time.

From backyard setups to large-scale projects, we're dedicated to improving human and environmental health. Blending innovation, reliability, and Aussie spirit, our solutions support families, businesses, and communities worldwide. With Australian roots and global reach, we're protecting the planet, supporting people, and shaping a sustainable future for generations to come.







Plumbing and Drainage Regulation 2019, part 4.

#### **Expertise**

With over 55 years of experience building our reputation, Taylex is the trusted voice for the wastewater industry. We work closely with the National Manufacturers Association and governing bodies to lobby for more stringent wastewater regulations. This ensures the highest level of treatment is met and provides you with the best results possible.

#### Integrity

We stand by our warranties, guaranteeing our products for their lifetime — no questions asked, no fine print. As an Aussie-owned, family-run business, we're dedicated to crafting high-quality products that work. We prioritise the well-being of our staff, while also respecting the environment and promoting human health.

#### Flexibility

At Taylex, we have a system that will work for you. Whether you're dealing with challenging terrain or unique soil conditions, our adaptable systems are designed to fit your home and block. We are eager to work with you and be your trusted solution.

#### Innovation

Taylex is at the cutting edge of environmentally sound wastewater treatment that is healthy and sustainable for your family and the environment. We are constantly testing and improving our systems to not only provide unparalleled quality and unmatched results but also to ensure the most stringent safety standards are met. We are continually striving to improve and perfect.

#### Functionality

Our Systems work! Taylex uses Monolithic, single-piece moulds meaning no deteriorating seals or weak post-joined walls, which could expose your family to catastrophic failure of your system. There's no skimping on parts from the biggest pump down to the smallest seal. Our systems are designed and engineered to last as long as your home.





Plumbing and Drainage Regulation 2019, part 4.

# What is a Wastewater Treatment System?

Our Wastewater Treatment Systems offer a safe, environmentally friendly, reliable, and cost-effective solution for your home. Our advanced systems use natural processes to transform household wastewater into clear, odourless water.

Our Taylex ABS are the most commonly used systems in Australia. They treat your wastewater to a high standard, making it possible to reuse water near your home and neighbouring properties, often above ground, with complete confidence.

Our systems are designed to handle all the wastewater from your home, including sewage (black water) from toilets and bidets, and sullage (grey water) from sinks, washing machines, dishwashers, showers, and baths. Your Taylex ABS sustainably treats wastewater by using the natural bacteria already present in the water. The system holds the wastewater in compartments where bacteria can thrive and naturally purify the water — without relying on harmful chemicals or additives.

Secondary Wastewater Treatment Systems are sometimes known by different names in different areas.

#### Here are some of the names you might have heard;

Home Sewage Treatment Plant (HSTP)
Secondary Treatment System (STS)
On-site Sewage Facilities (OSSF)
Aerated Wastewater Treatment Systems (AWTS)
Aerobic Treatment Units (ATU)
Aerobic Septic Systems
Wastewater Treatment Systems





Plumbing and Drainage Regulation 2019, part 4.





Plumbing and Drainage Regulation 2019, part 4.

## How does my Taylex System work?

All household wastewater from your bathrooms, toilets, kitchen, and laundry naturally flows into your Taylex ABS using gravity.

#### **Step One**


The first stop for your household wastewater is in the 'Primary Chamber'. Here solids will naturally sink to the bottom and fats and oils will naturally float to the top, leaving a clearer 'Supernatant Zone' in the middle. This zone will transfer to the next stage of treatment.

#### **Step Two**

Next is the 'Secondary Chamber'. Further settling happens here. Again, water from the middle flows onto the next stage, where there is an additional 'Bio-Mass' block in this chamber to assist with the separation of solids. In a traditional Septic System, this is where the journey would end and effluent would now be pumped onto your property and into our environment without any form of disinfection, relying on sand or soil to do the rest. With a Taylex ABS, there are still four more steps to produce clean, clear, and safe water for your yard.

#### **Step Three**

The 'Aeration Chamber' is next up. This is where the magic happens. Your quiet, reliable, energy-efficient 'Air Blower' sends oxygen into the chamber in the form of tiny bubbles. These bubbles pass through a specially designed structure called 'Bio-Mass'. 'Bio Mass' is purpose-designed to trap air bubbles to feed naturally occurring 'Aerobic bacteria'. These microscopic eco-warriors are now hard at work, chomping through most of the remaining organic matter, polishing the water, and eliminating odour.









Plumbing and Drainage Regulation 2019, part 4.

#### Step Four

Step four is in the 'Clarification Chamber'. More settling occurs here. Once settled to the bottom, this potent mix of 'Aerobic bacteria' and fine particle solids are recirculated to the 'Primary Chamber' to keep it healthy and working hard (not smelly).

#### Step Five

The final step in the treatment process is the 'Disinfection Chamber'. The water gets a 'kiss' goodbye from our 'Chlorinator'. Using the same amount of chlorine found in drinking water, the system removes any harmful bacteria, viruses and pathogens.

#### Step Six

Lastly, when the 'Disinfection Chamber' fills up, your dependable irrigation pump automatically switches on to send your water out to do its job in your yard. Crystal clear water irrigates your designated area and returns safely to nature, contributing to a healthy water cycle.







## **TREATMENT PLANT APPROVAL 17/2025**Plumbing and Drainage Regulation 2019, part 4.





Plumbing and Drainage Regulation 2019, part 4.





Plumbing and Drainage Regulation 2019, part 4.

## What Keeps my System Healthy?

#### Food

Your household wastewater is rich with organic matter that nourishes the good bacteria in your Taylex ABS. 'Food' comes from toilets, hand basins, sinks, showers, washing machines, in fact, anything natural that we put down the sink or flush down the toilet.

#### Air

Your Taylex ABS is fitted with a 'Air Blower' that takes fresh air and introduces it to the water through an aerator diffuser. The oxygen in the air dissolves into the water as it bubbles up to the top. This gives the water a higher-than-normal dissolved oxygen content allowing the good bacteria to breathe, live, and treat your wastewater.

#### Regular Servicing

For your Taylex ABS to work to the best of its ability, it needs to be serviced every 3 months. Not only is this regulation, but it guarantees your system is getting the adequate care it needs.







Plumbing and Drainage Regulation 2019, part 4.

## What Upsets the Balance in my System?

The greatest cause of problems for your Taylex ABS are harmful cleaning products and the washing machine. When using household cleaning products, please remember to:

- Adhere to the cleaning product manufacturer's recommended measured dosage. Do not free pour.
- Use cleaning products that are 'biodegradable', 'low-phosphorus' and labelled 'Safe for on-site treatment systems'.

#### **Antibiotics**

Never pour **antibiotics** down the sink or flush down the toilet. This can cause problems throughout your system.

#### Cleaning Products

The good bacteria in your Taylex ABS may class certain cleaning products as poisons if high levels are used. Please always use 'eco-friendly' products. Your Taylex ABS relies on bacteria for it to work effectively, therefore any product labelled as 'anti-bacterial' can be harmful to your system if used frequently or in large doses. Any bleaches or harsh chemicals should only be used once a week and in small doses if required. The use of harsh chemicals at high levels can affect the function of your system.

#### Washing Machines

Try to evenly spread your washing over the week. Avoid, where possible, washing everything in one day. It puts a large amount of water into your treatment system all at once and puts unnecessary strain on your system. Liquid soaps break down more easily than powder. Only use the amounts as outlined on the label.





Plumbing and Drainage Regulation 2019, part 4.

## Suitable Products

#### **Dishwashing Liquids**

As a rule of thumb, it is always recommended to go for dishwashing liquids labelled as 'environmentally friendly' or 'green'. In general, products that are 'non-toxic', 'non-chlorine based', and 'biodegradable' are considered safe.

#### Surface Cleaners

Similar to the above, it's suggested to look for 'environmentally friendly' products. It is also important to look out for products that are 'non-antibacterial' or harsh chemically.

#### **Toilet Cleaners**

The majority of cream cleaners are usually deemed suitable. Similarly, you want to look for products that are 'biodegradable', 'natural', and 'environmentally friendly'. Toilet fresheners are not recommended.

#### Floor Cleaners

It is recommended to use hot soapy water to clean floors. Using floor cleaners is generally acceptable at controlled levels. It's advised to stay away from heavy chemical cleaners.

#### Laundry Powders, Liquids and Bath Salts

Select 'low-phosphorus, sodium and sulphur products'. Washing soda can occasionally be added (less than half a cup) to help reduce foaming if necessary. When using Epsom salts in your bath, use small amounts, less than 2 cups of Epsom salt per bath, no more than once per week.

#### Pet/Animal Washing In Basins

Pets are treated with products to maintain their health (especially fleas). If washed in a laundry, bath, or shower, the treatment used could flow through to your system and cause operational problems.





Plumbing and Drainage Regulation 2019, part 4.

#### **Personal Hygiene**

When considering products to use for soaps and body wash we strongly advise looking for the following; organic ingredients, 'PH balanced', 'low-phosphorous' or 'phosphorous-free', 'non-toxic', 'low-sodium', 'low-sulphur', and 'biodegradable' products.

#### Too Much Of Anything Is A Bad Thing

When using cleaning products in your home, always remember that too much of anything can harm the good bacteria in your system. Moderation is key.

#### A Note On 'Greywater and Septic Safe'/'Biodegradable'

Whilst most of the time products labeled as 'greywater safe', 'septic safe', or 'biodegradable' are safe for use in your treatment system. Many plant-based cleaners are powerful antibacterials. Some products marketed as 'green' or 'biodegradable' can be more damaging to our environment than more traditional cleaning products. When selecting cleaning products, if in doubt, always look for products that are 'phosphate-free' or 'low-phosphate'.

#### Please Note

If your technician notices there is a problem, they may recommend that you limit the use of specific products (even if it is listed here as suitable).

Taylex promotes the use of 'low-phosphorus', 'phosphorus-free', 'low-sodium' and 'low-sulphur' products. This practice will reduce the phosphorus levels released into the environment and prolong the life of your phosphorus removal filter (if fitted).





## **TREATMENT PLANT APPROVAL 17/2025**Plumbing and Drainage Regulation 2019, part 4.





Plumbing and Drainage Regulation 2019, part 4.

## **Products to Avoid**

To keep you and your family safe, it is recommended to avoid or limit the use of these products in your Taylex ABS:

#### **Strong Antibacterials**

Cleaning products that contain any of the following should only be used in small doses in your Taylex ABS; bleaches, disinfectants, whiteners, chlorine, and 'anti-bacterials' (natural anti-bacterials such as Eucalyptus and Tea-tree oils included).

#### Caustic Oven or Drain Cleaners

Drain cleaners can do more harm than good for your system. If you want to safely clean your drains, we recommend the traditional method of vinegar and baking soda as a safe and effective alternative.

#### Sanitary Products

Products such as **nappy liners**, **sanitary pads**, **condoms**, **ANY wipes**, and **'non-biodegradable' sanitary products** should never be flushed, as they will not break down in your system.

#### Kitchen Related Products

Avoid putting things such as **dairy products**, **cooking oils**, **excess food scraps**, and anything from your **home brew kit** down the sink, drain or, toilet. **Garbage disposals** are not permitted to be used with any Taylex ABS.

#### **Excess Water**

Using too much water in one go can be bad for your system. It can cause the system to block or not flow as efficiently as it should. As a result, your system can shut down or smell. To avoid this, spread out activities that require high water usage, such as doing the laundry or dishes and taking baths/showers.

#### Other Things To Avoid

Never put, automotive oils, hair dyes, antibiotics, bandages, dead fish/small animals, and hair down the sink, drain or toilet. Doing so can cause extensive damage to your system.





Plumbing and Drainage Regulation 2019, part 4.

## Servicing your Taylex System

Most Wastewater Treatment Systems are required to be serviced quarterly and may only be serviced by licensed wastewater service personnel. In addition to keeping your Taylex ABS running to the best of its ability, Taylex servicing will also:

- Ensure that all council reporting requirements are met.
- Send your service reports to your local council on your behalf (where required).
- Send your reports and invoices to you electronically (when possible).
- Provide spare parts to current contract holders at a discounted rate.
- ✓ Offer an extended warranty of 3 years for electrical and mechanical parts if you hold a current service contract and the parts were installed by us. The standard warranty is 12 months.
- ✓ In the unlikely event of a breakdown or emergency, we prioritise call-outs for our current customers and charge at a discounted rate.

#### How can you assist in servicing your Taylex System?

- ✓ Not cover the top of the tank with decking, earth, gravel, mulch, concrete, pavers, pot plants, barbecue, swing set, seats, etc.
- Provide clear, safe access to the system and the inspection openings.Ensure that plants, trees, and grass around the system are trimmed and cut.
  - Provide your service person with a key, if you have a locked yard and you
- are not going to be present during the service.
  - Make sure surface water does not pool and can never enter the tank, even
- during torrential rain events.

18





Plumbing and Drainage Regulation 2019, part 4.

# Operating Instructions - ABS Eco Controller

#### Introduction


The 'Taylex ABS Eco Controller' has several features that are explained in this section.

The 'Eco Control Panel' monitors and controls the Taylex ABS' air blower, and pump and registers an alarm when it detects a fault in the system.

The 'Taylex ECO Controller Assembly' (complete with Controller, Control Panel Box, 3 x GPO Assembly and Blower Box) is classed as electrical equipment and has been certified to comply with AS/NZS3820 and AS/NZS 3100:2017, meeting the Electrical Safety requirements in Australia and New Zealand. Your Taylex ABS is designed to operate automatically and its operation will usually be event free. The 'Eco Control Panel' provides visual and audible indicators of both normal operating conditions and fault conditions.

#### **Normal Operation at Start-up**

When the power is switched on to your 'Taylex ABS Eco Control Panel', the display (A) will flash twice. The audible alarm will sound in unison with the 2 flashes, this is a 'Test Mode'. At the completion of the 'Test Mode', the display will show a single green light in the 'Power' indicator to indicate that the system has tested correctly and is in normal operation.








Plumbing and Drainage Regulation 2019, part 4.

#### The Power Supply

The power outlets for the 'ECO Controller' for your system are located inside the 'Blower Box'. Each switch must be in the ON position at all times. If any or all switches are OFF, the treatment process and alarms may not function. The single GPO is for the 240V – 12V power supply for your controller and the double GPO is for your Pump and Blower. The double GPO contains a 7amp breaker underneath the GPO, which will activate in the case of a fault with the pump and/or blower. If the breaker is activated it will trigger the associated alarm on the Controller. You can reset the Breaker by pushing the reset button (see page 16 for full instructions). If the breaker is activated again, please contact your Service Agent to rectify the issue.



#### **Optional Extra**

A 12V 'In-House Alarm Panel' is available as an optional extra to the system. If required, the panel can be fitted during the installation of the system. The 'In-House Alarm Panel' is connected to the same circuit as the Alarm, situated on the system, and works in tandem with the same functions listed above. To mute the 'In-House Alarm', press the red button, this will silence the alarm. The alarm at the system will still function and needs to be muted separately. The LED light on the 'In-House Alarm Panel' will continue to flash until the fault is rectified.







Plumbing and Drainage Regulation 2019, part 4.

## **OPTIONAL Back to Base Alarm Modem**

The range of Taylex ABS systems offers the option to include a Back-To-Base Alarm Modem. If supplied with the system, it will be located behind the control panel, mounted on the side of the blower box.

This modem notifies the customer or service agent of any system alarms via SMS, sending alerts to up to three pre-programmed contact numbers. In the event of a power loss, the built-in backup battery ensures continued operation and triggers a 'No Power' alarm. Once the issue is resolved, a follow-up SMS is sent to confirm that the system has returned to normal operations.

#### **Set-Up Instructions**

The modem comes with a SIM card, allowing it to send SMS alarm alerts to the pre-programmed contact numbers once set up.

The SIM card is located in the slot with the gold SIM conductor pins facing down. Push the SIM card in until it locks into place. To remove the SIM card, simply push it in again and it will unlock.



Present the SIM number provided with the modem to any Telstra outlet to activate the SIM. Once activated you will receive a phone number for the modem. We recommend using a pre-paid plan. It is the owner's responsibility to ensure the SIM has sufficient credit for SMS alerts to be sent.

**To close**, slide the cover back to the left, and then push the right-side flap closed.

To lock the protective cover, on the back of the modem, fasten the provided Torx screw into the hole on the bottom of the device using a T6 Torx driver.



#### Phone Number Programming

To store your numbers in the modem, simply send this SMS message to the number associated with the SIM card inside the modem: TN\*phonenumber1\*phonenumber2\*phonenumber3\*

To check/search for stored numbers on the modem, simply send this SMS message to the number associated with the SIM card inside the modem: PB





Plumbing and Drainage Regulation 2019, part 4.

## Alarm Codes (Trouble Shooting)

Alarm	Meaning	Action
1 Flash	Normal Operation	None required
3 Flashes	The water level is high	Please see below
5 Flashes	There is no airflow	Call your Service Agent
3 & 5 Flashes	Tripped Circuit Breaker	Reset Breaker or call your Service Agent

#### 3 Flashes - High Water Alarm

A high water level may be self-correcting. It can be caused by multiple sources of water coming in, overloading the system. If you think this may have occurred, then wait for 15 minutes until the surge flow has stopped and see if the alarm stops. If sprinklers are still operating (if applicable), recheck the alarm when they stop to see if the alarm has stopped. If it does not then check the following:

- 1. Is there a filter on the irrigation line before the effluent disposal area? Is it blocked?
- 2. Is the irrigation line kinked or broken?
- 3. Has the irrigation pump failed?
- 4. Surface irrigation Are all the turf valves connected?

If you can rectify any of these problems yourself, then you will save the call-out cost of your Service Provider. However, they are experts in this field and will assist you whenever you need their help. Call them whenever you need their assistance or you are in doubt about what you need to do. They will happily assist you over the phone.

#### 5 Flashes - No Air Flow

When your alarm has 5 flashes it means no air flow. This is usually an indication that the blower is not working properly. This can be caused by a range of things, for example, if your system short circuits.

If this alarm is activated for your system, we suggest you call your local Wastewater Specialist.






Plumbing and Drainage Regulation 2019, part 4.

#### 3 & 5 Flashes - Tripped Circuit Breaker

When your alarm has 3 and 5 flashes, this means you have a tripped circuit breaker. This can be caused by issues with the aerator or other electrical components. If this happens refer to the diagram below and reset the breaker.

#### Resetting the Breaker

- Remove the 4 screws on the blower box.
- 2. Underneath the double power point locate the button as shown below.
- 3. Turn OFF both switches (1 = Pump & 2 = Blower)
- 4. Push in the RESET button and wait 10 seconds.
- 5. Switch ON switch 1 and wait 10 seconds.
- 6. Switch ON switch 2 and wait 10 seconds.
- If the circuit breaker 'Trips' when either one of the switches is turned ON, this would indicate there is a problem with the pump or blower. Leave the faulty switch in the OFF position and notify your service agent immediately.
- 8. If the system doesn't alarm, monitor for the next 3 days.
- 9. If the system continues to alarm, call your local Wastewater Specialist.







Plumbing and Drainage Regulation 2019, part 4.





Plumbing and Drainage Regulation 2019, part 4.

## **Resetting your Taylex System**

If you have identified an issue, once it is fixed you can try resetting your system:

- Turn the system OFF, remove the 4 screws on the (Blue or Green) blower box cover and turn the single power point ONLY OFF. This will reset the program.
- 2. Turn the system ON again using the single power point switch.
- 3. If the system starts and operates correctly, observe the system over the next few days for another ALARM event and discuss it with your Service Agent.
- 4. If the system goes back into ALARM mode, call your Service Agent. Limit your water usage until the fault is rectified.

Contact your local Wastewater Specialist.

taylex.com.au 1300 TAYLEX

# Visit our website to see if theres a troubleshooting guide for you.



Scan the QR code for our Servicing Page

## Warranty




Scan the QR code for the latest info






Plumbing and Drainage Regulation 2019, part 4.





Plumbing and Drainage Regulation 2019, part 4.





Plumbing and Drainage Regulation 2019, part 4.



Your local Wastewater Specialist:					

Owner's Manual for the Advanced Blower System

#### **Head Office**

Taylex Australia Pty Ltd 56 Prairie Rd, Ormeau QLD 4208 ABN 43 646 051 989

Phone

1300 TAYLEX **Web** TAYLEX.COM.AU

V1.1 - JANUARY 2025





Plumbing and Drainage Regulation 2019, part 4.

#### Attachment 3 - PABS 1500 - Schematic diagrams

